

GV2ME03

MANUAL STARTER AND PROTECTOR 0 25-0 40

Main

Ampere Rating	25A
Approvals	UL Listed File Number: E164864 NLRV - CSA Certified File Number: LR81630 Class: 3211 05 - CE Marked
Marketing Trade Name	TeSys
Maximum Voltage Rating	600VAC
Operator Type	Pushbutton
Overload Type	Ambient Compensated Bimetallic
Short Circuit Current Rating	50kA@480V - 30kA@600V
Terminal Type	Screw Clamp
Thermal Trip Setting	0.25A to 0.40A
Type	GV2