



Main

| | |
|------------------------------------|-----------------------|
| Range of product | Harmony XVB Universal |
| Product or component type | Indicator bank |
| Beacon or indicator bank unit type | Audible unit |
| Mounting diameter | 70 mm |
| Component name | XVBC |
| Noise level | 70...90 dB at 1 m |
| [Us] rated supply voltage | 120...230 V AC |

Complementary

| | |
|--|--|
| Signalling type | Continuous or intermittent buzzer |
| Assembly style | Customer assembly, up to 5 units |
| Connections - terminals | Screw clamp terminals: $\leq 1 \times 1.5 \text{ mm}^2$ with cable end |
| [Ui] rated insulation voltage | 250 V conforming to IEC 60947-1 |
| Nominal voltage limit | 0.85...1.1 U_n conforming to IEC 60947-5-1 |
| Current consumption | < 25 mA |
| [Uimp] rated impulse withstand voltage | 4 kV conforming to IEC 60947-1 |
| Fundamental frequency | 2.8 kHz |
| CAD overall width | 70 mm |
| CAD overall height | 63 mm |
| CAD overall depth | 70 mm |
| Product weight | 0.18 kg |

Environment

| | |
|---------------------------------------|---|
| Product certifications | CSA C22-2 No 14 UL 508 CCC GOST |
| Standards | EN/IEC 60947-5-1 |
| Protective treatment | TC |
| Ambient air temperature for storage | -40...70 °C |
| Ambient air temperature for operation | -25...50 °C |
| Electrical shock protection class | Class I on support tube conforming to IEC 61140 |

Class II on base unit conforming to IEC 61140

| | |
|---------------------------|---|
| IP degree of protection | IP65 on fixing base XVBZ0. conforming to IEC 60529 IP66 on base unit conforming to IEC 60529 |
| NEMA degree of protection | NEMA 4X (indoor) conforming to UL 508 |

Contractual warranty

| | |
|-----------------|-----------|
| Warranty period | 18 months |
|-----------------|-----------|
